

**KEY**

**Carriageway works:-**  
Provide and lay 100x100x150 Granite Setts GRA 903 Flamed Sawn Finish with staggered joints and flush pointing on 40mm 'Steintec' bed on 200mm C32/40 PQ concrete slab with B1132 Structural Fabric in top face. On an approved separation membrane on 200mm, Type 1 subbase to Clause 803 of the specification. (Assuming a CBR value of > 5%). Colour of blocks to be agreed.

**Loading bay works:-**  
Provide and lay 200x100x150 York Stone Setts Sawn Finish with staggered joints and flush pointing on 40mm 'Steintec' bed on 200mm C32/40 PQ concrete slab with B1132 Structural Fabric in top face. On an approved separation membrane on 200mm, Type 1 subbase to Clause 803 of the specification. (Assuming a CBR value of > 5%). Colour of blocks to be agreed.

**New Raised Crossing Ramp Construction comprising:-**  
Plane off 25mm, existing surfacing. Relay to new levels with 35mm Stone Mastic Asphalt (SMA) wearing course to Clause 970AR of the Specification, 60mm, of 20mm size dense binder course to Cl 6.5 of BS4987-1:2001 as necessary. Binder course regulating as required.

**Footway works:-**  
Provide and lay concrete blocks 200x100x80mm. Blocks to be laid on 25mm compacted thickness of mortar designation (i) to Clause 2404 of the Specification. On 200mm, concrete Mix ST1 on 150mm, Type 1 subbase to Clause 803 of the specification. Colour of blocks to be agreed.

**Footway works:-**  
Provide and lay 900x600x63 natural standard concrete paving square edged, with staggered joints and flush mortar. Slabs to be laid on 25mm compacted thickness of mortar designation (i) to Clause 2404 of the Specification. On 200mm, concrete Mix ST1 on 150mm, Type 1 subbase to Clause 803 of the specification. Colour of slabs to be agreed.

**Grey coloured tactile paving blister slabs (400x400x75mm.)**  
laid in accordance with the 'Guidance on the use of Tactile Paving Surfaces' 1998. Slabs to be laid on 25mm compacted thickness of mortar designation (i) to Clause 2404 of the Specification, which in turn will be placed on 150mm Granular Type 1 subbase to Clause 803 of the Specification.

**Drainage Channel works:-**  
Provide and lay 3 rows of 200x100x75 concrete blocks square edged, with parallel joints and flush mortar. Slabs to be laid on 25mm compacted thickness of mortar designation (i) to Clause 2404 of the Specification. On 200mm, concrete Mix ST1 on 150mm, Type 1 subbase to Clause 803 of the specification. Colour of blocks to be agreed.

**Proposed tree, (type to be agreed), CEDEC Composite crushed granite and quartz gravel laid within the tree pits with 'Charcon' natural granite kerb stones for the surround. Position showed is indicative only, final location to be agreed with L.B. of Lambeth's Engineer.**

**300x1200x250 deep Granite kerb GRA 903 Fine Picked Sawn Finish.**

Extra 10.2m.  
of Parking

H	07.12.16	Road markings to B & Q entrance amended	HAL	JEB
G	06.12.16	Materials in Waylett Place & Safety Audit changes	HAL	JEB
F	28.11.16	Dropped crossing added in Waylett Place	HAL	JEB
E	15.11.16	Double yellow lines extended across raised tables	HAL	JEB
D	14.11.16	Roadmarkings amended	HAL	JEB
C	06.10.16	Lane widths amended	HAL	JEB
B	19.09.16	Eastern footway widened & loading bay added	HAL	JEB
A	06.07.16	Roadmarkings added	HAL	JEB
REV	DATE	AMENDMENTS	BY	CHK



Project  
**'STREETWORKS' NORWOOD ROAD PHASE 1A**

Title  
**LANSOWNE HILL to WAYLETT GENERAL ARRANGEMENT (Sheet 2 of 2)**

Drawn By  
**HASWELL ASSOCIATES LTD.**  
55 Pollards Green Chelmsford Essex CM2 6UH  
Tel : (01245) 600123 Fax : (01245)600149

Drawn	Checked	Scale
HAL	JEB	1-100 (A0)

Date	Drawing No.
JUNE 2016	1614 / 3/02H

Haswell Associates Ltd. accept no responsibility for any unauthorised amendments to this drawing. Only figured dimensions are to be worked to. (COPYRIGHT © HASWELL)