

M915XE-AE / M9134E-AE OPERATING INSTRUCTIONS

ACSI M1520M-AE

Mortise lock with Authorized Egress (AE) Monitoring, also referred to as Request to Exit or RX Switch.

AE – AUTHORIZED EGRESS

The AE switch monitors the use of the INSIDE trim when the OUTSIDE trim is locked

ELECTRICAL SPECIFICATIONS

SPDT Mechanical Switch

<u>VOLTAGE</u>	<u>CURRENT</u>
125 VAC	1 AMP
30 VDC	0.5 AMP

NOTE: Mainly used as a dry contact monitoring switch

WIRING DIAGRAM

YELLOW WIRE – Common
RED WIRE – Normally Open
GRAY WIRE – Normally Closed

