## Certificate of Compliance

E CAMPACE NA COLOR DAMES

No. 0H181119.RESQQ19

Test Report no. XMT0201803526L/LVD, XMT0201803527L/EMC

Certificate's

**REVALCO ELECTRIC SPAIN** 

Holder:

Polígono Industrial Sur C/ Plomo 10 - Nave C, 28770 -

Colmenar Viejo, Madrid, Spain

Certification FCM Mark:



Product:

Miniature Circuit Breaker

Model(s):

RV30 Basic model and RV30 Normal Model

Ue=240/415V~(1P),240V~(1P+N),415V~(2P,3P,3P+N,4P) In=1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A B-, C- and D- Type IEC 60898-1:lcs=lcn=6000A,Energy limiting class 3(Only for B,C type) IEC 60947-2:lcn=10000A, Ics=7500A,Energy limiting class 3(Only for B,C type)

Verification to:

Standard:

IEC 60898-1:2015, IEC 60947-2:2016, EN 61000-3-2:2014, EN 61000-3-3:2013,

EN 61000-6-1:2007, EN 61000-6-3:2007+A1:2011

related to CE Directive(s): 2014/35/EU (Low Voltage)

2014/30/EU (Electromagnetic Compatibility)

**Remark:** The product(s) has been verified on a voluntary basis. The product(s) satisfies the requirements of the Certification Mark of ECM, in reference to the above listed Standard(s). The above Compliance Mark can be affixed on the product(s) accordingly to the ECM regulation about its release and its use. The regulation can be found at www.entecerma.it. This Certificate of Compliance can be checked for validity at www.entecerma.it

This verification doesn't imply assessment of the production of the product(s).

Additional information, clarification about the CE Marking:



We attest that a TCF for the CE Marking process is in place. Whereas the Manufacturer is Responsible to start the CE Marking Certification Procedure and to perform all the necessary activities, as required by the Directive before placing the CE Mark on the product(s).

Date of issue 19 November 2018

Expiry date 18 November 2023



